

Llano Masonry

4801 122nd
Lubbock, TX 79424
806-771-9510

Submittals

Project: Texas Tech University Chapel

Architect: McKinney York Architects

General contractor: Western Builders


Specification: 044300-5

Item: stone anchors


Manufacturer: Holman & Barnard

Description: stainless steel anchors

Notes: We propose to use all stainless steel anchors. At locations of banding and wall cap, we will use an anchor pin. At locations of larger bands, soffits and projections we will use a split-tail anchor installed at head joints.




2 SECTION - FLUSH TOWER LEDGE @ SLAB
1 1/2" = 1'-0"





STAINLESS STEEL STONE ANCHORS

#406 STONE ANCHOR



QUANTITY:

ST/ST Rounds Min. Fy. = 75,000 p.s.i. (ASTM A580)

DRAWINGS FOR ILLUSTRATIVE PURPOSES ONLY

FINISH:

- ☐ TYPE 304 Stainless Steel
☐ TYPE 316 Stainless Steel

DIAMETER:

- | | | |
|---------------------------------------|---------------------------------------|--------------------------------------|
| ☐ 3/16"/4.7 mm | ☐ 3/8"/9.5 mm | ☐ 3/4"/19 mm |
| ☐ 1/4"/6.3 mm | ☐ 1/2"/12.7 mm | ☐ OTHER _____ |
| ☐ 5/16"/7.9 mm | ☐ 5/8"/15.8 mm | |

H&B recommends the exclusive use of 304 or 316 ST/ST for stone anchorage.

PROJECT NAME:

LOCATION:

NOTES:

CONTACT INFO

Name :

Company:

Phone:

Email:

FAX:

The appropriate selection and use of any product contained herein must be determined by competent architects, engineers and other professionals who are familiar with the specific requirements of the project.




Hohmann & Barnard, Inc.
800-645-0616 www.h-b.com

© HOHMANN & BARNARD, INC. - 2009



H&B STAINLESS STEEL STONE ANCHORS

#439 STONE ANCHOR



QUANTITY:

ST/ST Plate Min. Fy. = 45,000 p.s.i. (ASTM A666)

DRAWINGS FOR ILLUSTRATIVE PURPOSES ONLY

FINISH:

☐ TYPE 304 Stainless Steel

☐ TYPE 316 Stainless Steel

THICKNESS:

☐ 12 ga./4.8 mm

☐ 1/8"/3.2 mm

☐ 3/16"/4.7 mm

☐ 1/4"/6.3 mm

☐ 3/8"/9.5 mm

☐ OTHER _____

H&B recommends the exclusive use of 304 or 316 ST/ST for stone anchorage.

PROJECT NAME:

LOCATION:

NOTES:

CONTACT INFO

Name :

Company:

Phone:

Email:

FAX:

The appropriate selection and use of any product contained herein must be determined by competent architects, engineers and other professionals who are familiar with the specific requirements of the project.



Hohmann & Barnard, Inc.
800-645-0616 www.h-b.com

© HOHMANN & BARNARD, INC. - 2009